1	2	3	4	5
				यूनिट-4 अवसंरचनात्मक स्टील के उत्थापन कार्य/टर्बोजेनरेटर के कक्ष को तैयार करने में उत्थान कार्य की शुरुआत किए जाने में विलम्ब होना
2.	खदरी गैस आधारित सी०सी०जी०टी०	उ०प्र०	4×131 जी० टी०+ 2×146 एस०टी०	(क) आवंटित सी० एण्ड आई/चैक्सुल उपस्कर हेतु विदेशी मुद्रा के लिए साख पत्र खोलने में विलम्ब होना। (ख) डब्ल्यू०एच०आर०जी० के लिए मेसर्स द्वारा उपस्कर सप्लाई करने में विलम्ब होना
3.	फरक्का एस०टी०पी०पी०	प० बंगाल	3×500 मे०वा०	1. आयतर का फेल होना। ई०एस०पी० का हट जाना। 2. यूनिट-6 के लिए विश्व बैंक से वित्तीय सहायता उपलब्ध न होना।
4.	कहलगांव एस०टी०पी०पी०	बिहार	4×210	1. 9.10.92 को विस्फोट के कारण आयतर क्षति ग्रस्त होना 2. रत्नावली यू०एस०ए०एस०आर० से शेष सामग्री सप्लाई किए जाने में विलम्ब होना।
5.	तलचर एस०टी०पी०पी०	उड़ीसा	1×500 मेगावाट	1. कार्य स्थल पर तौशेगिक संबंधों की समस्याएं होना 2. शेष भूमि अधिग्रहण करना 3. उपस्कर सप्लाई न किया जाना

(ख) उपरोक्त परियोजनाओं की समयावधि बढ़ जाने से इनकी लागत में वृद्धि हुई है। तथापि, यमुना नगर और फरीदाबाद परियोजना लागत अभिवृद्धि से प्रभावित होने का प्रश्न नहीं उठता, क्योंकि अभी इन परियोजनाओं को सरकार द्वारा अनुमोदित किया जाना है।

(ग) इन परियोजनाओं के पूरा न होने से विद्युत की उपलब्धता प्रभावित होगी।

(घ) राष्ट्रीय ताप विद्युत निगम ने फरीदाबाद में 400 मेगावाट का संयुक्त साइकिल विद्युत संयंत्र अधिष्ठापित करने का प्रस्ताव रखा है, जिस पर तकनीकी-आर्थिक दृष्टि से स्वीकृति प्रदान किए जाने के लिए केन्द्रीय विद्युत प्राधिकरण द्वारा विचार किया जा रहा है। इसी बीच केन्द्रीय विद्युत प्राधिकरण ने परियोजना के लिए पर्यावरणीय स्वीकृति और गैस लिंकेज समेत उपेक्षित स्वीकृतियां प्राप्त कर ली हैं। परियोजना के लिए ओ०ई०सी०एफ० सहायता की प्रथम किस्त के रूप में, राष्ट्रीय ताप विद्युत निगम द्वारा क्रियान्वित किए जा रहे विद्युत केन्द्र के हिस्से के लिए 19.998 मिलियन जापानी येन और पावर ग्रिड द्वारा क्रियान्वित किए जा रहे पारेषण हिस्से के लिए 3.538 मिलियन जापानी येन समेत ओ०ई०सी०एफ० जापान ने परियोजना के लिए 23.5 मिलियन जापानी येन के ऋण की सुविधा प्रदान की है।

राष्ट्रीय ताप विद्युत निगम की हरियाणा के यमुना नगर में 840 मेगावाट कोयला आधारित विद्युत संयंत्र अधिष्ठापित किए जाने की आयोजना थी, जिसे अब निजी क्षेत्र में क्रियान्वित किए जाने का प्रस्ताव है।

Thermal Power Plant at Basin Bridge in Tamil Nadu

5527. SHRI V. GOPALSAMY-Will (he Minister of POWFR be pleased to state :

(a) whether there is any proposal to instal Thermal Power Plant at Basin Bridge in Tamil Nadu;

(b) if so, the details thereof;

(c) what is the installed capacity of the proposed plant:

(d) what is the estimated cost; and

(e) by when the project is likely to be commissioned ?

THE MINISTER OF STATE IN THE MINISTRY OF POWER (SHRI P. V. RANGAYYA NAIDU): (a) Yes, Sir.

(b) to (d) The proposal for installation of Gas Turbine Station (4 X 30 MW) at Basin Bridge was sanctioned by the Planning Commission in December, 1988 at an estimated cost of Rs. S6.48 crores for implementation by the Tamil Nadu Electricity Board (TNEB) as a State Sector project The latest estimated cost of this project (4 X 34 MW) is Rs.430.17 crores. The project isunder execution by the TNEB with Japanese assistance.

(e) The first unit is expected to be commissioned in 1994-95 and the remaining three units are expected to be commissioned during 1995-96.

Dual Pricing System in the Power Sector

5528. SHRI V. HANUMANTHA RAO: Will the Minister of POWER be pleased to state:

(a) whether Government propose to abolish dual pricing system in the power sector;

(b) if so. Treasons therefor,

(c) what would be its impact in Andhra Pradesh; and

(d) whether any study has been made on the impact of this policy in Andhra Pradesh ?

THE MINISTER OF STATE IN TOE MINISTRY OF POWER (SHRI P. V. RANGAYYA NAIDU): (a) There is no proposal with the Government to abolish the two-part tariff system for sale of electricity from Generation Stations.

(b) to (d) Do not arise in view of (a) above.

Power Generation in Gujarat

5529. SHRl ANANTRAY DEVSHANKER DAVE:Will the Minister of POWER be pleased to state:

(a) the quantum of power generated in Gujarat during the year 1992-93 and upto December, 1993;

(b) the actual requirement of power in that State; and

(c) the steps being taken by Government to bridge the gap between requirement and generation of power in that State ?

THE MINISTER OF STATE IN THE MINISTRY OF POWER (SHRI P. V. RANGAYYA NAIDU): (a) During the year 1992-93 and 1993-94 (upto December. 1993) the total energy generation in Gujarat was 24548 Million Units (MU) and 19706 MU respectively.

(b) The Energy Requirement in Gujarat during 1992-93 and 1993-94 (upto December, 1993) was 26500 MU and 22050 MU respectively.

(c) To generate additional power to meet the power requirements of the State, it is envisaged to add 620 MW capacity during the 8th Plan period. In addition, the State will also get its due share from the Central Sector Projects which are being established in the Western Region. Various other measures taken to improve the availability of power in Gujarat include maximising the generation from the existing generating stations, implementation of Renovation and Modernisation programme of generating stations, reduction in Transmission and Distribution losses, effective load management and conservation of energy etc. Assistance is also made available to Gujarat from the neighbouring systems whenever system conditions are conducive to such transfer.

Two Part Tower Tariff System

5530. SHRI VIREN J. SHAH:
SHRI PRAMOD MAHAJAN :

Will the Minister of POWER be pleased to state:

(a) whether Government propose to do away with the two part power tariff system; if so, what are the details in this regard;

(b) whether Government propose to in-